

ATTENTION



Behavior in case of transport damage

- ▶ Check the device for transport damage such as deformations or loose parts.
- ▶ In case of damage immediately contact the carrier.
- ▶ Do not operate a device with transport damage!

ATTENTION



Getting the documentation

Hazards and risks due to ignorance

- ▶ Visit the KEB homepage at www.keb.de.
- ▶ By entering the material number in the search area you will get the corresponding parts of the instruction manual.
- ▶ Read the instruction manual detailed!
- ▶ Observe the safety and warning instructions!
- ▶ In case of uncertainties, please contact service@keb.de!

⚠ DANGER



Interventions by unauthorized personnel!

Danger to life by electric shock and malfunctions!

- ▶ Modification or repair is only permitted by KEB authorized personnel.
- ▶ Switch off the supply voltage and secure it against restarting before starting any work on the device.
- ▶ Wait until the drive has stopped so that no regenerative energy can be generated.
- ▶ Wait for capacitor discharge time (5 minutes), if necessary measure DC voltage at the terminals.



Devices with FS, UL or UR marks on the type plate are subject to special regulations. Observe the instructions in the instruction manual.